

## Classification Report

Number	17-003150-PR02 (NW 01-C01-02-en-01)
Owner	ViewMax Windows and Doors Co. Ltd. Huaxin Industrial Park, Yanggu 252323 Shandong China
Product	Single leaf external pedestrian doorset with side light, inward opening
Designation	System: Viewmax aluminium system - AVS Shipping name: PK Single sash plus fix
Details	Material Aluminium; Overall dimensions (W x H) 1600 x 2200 ; Closing condition closed, locked and secured; Threshold: Designation RHM270531, Shandong Huajian aluminium group co. LTD.; System AVS (Aluminium plus Thermal bridge); Material Aluminium; Lock: Designation 2MF-BO U-6/24/6, MACO
Special features	Watertightness was carried out with additional floor simula- tion (reduced water level).

### Result

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C4/B4**

Watertightness according to EN 12208:1999-11



**Class: 2A**

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
e.g. DIN EN)

Test report: 17-003150-PR02 PB  
01-C01-02-de-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim  
29.05.2018



Andreas Graf, MSc, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Component Testing



Daniel Gromotka, B.Eng.  
Operating Testing Officer  
Building Component Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 503-548D1